

JONES WATER SUPPLY CORPORATION

2014 Annual Drinking Water Quality Report
Consumer Confidence Report (CCR)

**Annual Water Quality Report for the period of January 1 to
December 31, 2014**

Public Water System ID Number: 2500007

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water.

**For more information contact Frances Delk at
903-967-2840.**

Este informe contiene información muy importante sobre el agua que usted bebe. Tradúzcalo ó hable con alguien que lo entienda bien.

Special Notice Required Language for ALL Community Public Water Supplies:

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the system's business office.

You may be more vulnerable than the general population to certain microbial contaminants, such as Cryptosporidium, in drinking water. Infants, some elderly, or immunocompromised persons such as those undergoing chemotherapy for cancer; those who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care provider. Additional guidelines on appropriate means to lessen the risk of infection by Cryptosporidium are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Jones WSC is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimum exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

The source of drinking water used by JONES WSC is Ground Water. It comes from the Wilcox Aquifer, Carrizo Sand.

Information on Sources of Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff and septic systems.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

Information about Secondary Contaminants

Many constituents (such as calcium, sodium, or iron) which are often found in drinking water can cause taste, color, and odor problems. The taste and odor constituents are called secondary constituents and are regulated by the State of Texas, not the EPA. These constituents are not causes for health concern. Therefore, secondaries are not required to be reported in this document but they may greatly affect the appearance and taste of your water.

Public Participation Opportunities

Date: Board Meeting 4th Monday, Quarterly

Time: 5:30 P.M.

Location: Office – 1650 N ST HWY 37
QUITMAN, TX 75783

Phone Number: 903-967-2840

To learn about future public meetings (concerning your drinking water), or to request to schedule one, please call us.

Information about Source Water Assessments

A Source Water Susceptibility Assessment for your drinking water source(s) is currently being updated by the Texas Commission on Environmental Quality (TCEQ). This information describes the susceptibility and types of constituents that may come into contact with your drinking water source based on human activities and natural conditions. The information contained in the assessment allows us to focus source water protection strategies.

The TCEQ completed an assessment of your source water and results indicate that some of your sources are susceptible to certain contaminants. The sampling requirements for your water system are based on this susceptibility and previous sample data. Any detection of these contaminants may be found in this Consumer Confident Report. For more information on source water assessments and protection efforts at our system, contact Frances Delk.

For more information about your sources of water, please refer to the Source Water Assessment Viewer available at the following URL: <http://gis3.tceq.state.tx.us/swav/Controller/index.jsp?wtrsrc=>

Further details about sources of source water assessments are available in Drinking Water Watch at the following URL: <http://dww.tceq.texas.gov/DWW>

<u>Source Water Name</u>	<u>Type of Water</u>	<u>Report Status</u>	<u>Location</u>
1 – Forest Hill	GW	A	7650 N ST HWY 37, Quitman, TX 75783
2 – A Well	GW	A	4389 W FM 515, Quitman, TX 75783
3 – Forest Hill Remote/N of Plant 1	GW	A	1650 N ST HWY 37, Quitman, TX 75783
4 – WB Well	GW	A	1650 N ST HWY 37, Quitman, TX 75783
5 - Irons Well (FM 14/2088)	GW	A	340 CR 3135, Quitman, TX 75783
6 – C Well	GW	A	4398 W FM 515, Quitman, TX 75783
7 – Hicks Well/CR 3118	GW	A	1449 CR 3118, Quitman, TX 75783

Lead & Copper	Year	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	2013	1.3	1.3	0.437	0	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of Household plumbing systems.
Lead	2013	0	15	1.88	0	ppb	N	Corrosion of household plumbing systems; Erosion of natural deposits.

Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.

Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Water Quality Test Results

Definitions: The following tables contain scientific terms and measures, some of which may require explanation.

Maximum Contaminant Level Goal or MCLG: The level of contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Contaminant Level or MCL: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Residual Disinfectant Level Goal or MRDLG: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Maximum Residual Disinfectant Level or MRDL: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

ppm: milligrams per liter or parts per million – or one ounce in 7,350 gallons of water.

ppb: micrograms per liter or parts per billion – or one ounce in 7,350,000 gallons of water.

pCi/L: picocuries per liter. (a measure of radioactivity)

AvG: Regulatory compliance with some MCLs are based on running annual average of monthly samples.

MFL: million fibers per liter (a measure of asbestos)

NTU: nephelometric turbidity units (a measure of turbidity)

ppt: parts per trillion, or nanograms per liter(ng/L)

ppq: parts per quadrillion, or picograms per liter (pg/L)

