

JONES WATER SUPPLY CORPORATION
2021 Annual Drinking Water Quality Report
Consumer Confidence Report (CCR)

Annual Water Quality Report for the period of January 1 to December 31, 2021

Public Water System ID Number: 2500007

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water.

For more information contact Frances Delk at 903-967-2840.

Este reporte incluye información importante sobre el agua para tomar. Para asistencia en español, favor de llamar al teléfono 903-967-2840

Special Notice
Required Language for ALL Community Public Water Supplies:

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the system's business office.

You may be more vulnerable than the general population to certain microbial contaminants, such as Cryptosporidium, in drinking water. Infants, some elderly, or immunocompromised persons such as those undergoing chemotherapy for cancer; those who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care provider. Additional guidelines on appropriate means to lessen the risk of infection by Cryptosporidium are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Jones WSC is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for

30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimum exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>

The source of drinking water used by JONES WSC is Ground Water. It comes from the Wilcox Aquifer, Carrizo Sand located in Wood & Hopkins County.

Information on Sources of Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick-up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff and septic systems.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

Public Participation Opportunities

Date: Board Meeting 4th Monday, Quarterly
Time: 5:30 P.M.
Location: Office – 1650 N ST HWY 37
QUITMAN, TX 75783
Phone Number: 903-967-2840

To learn about future public meetings (concerning your drinking water), or to request to schedule one, please call us.

Information about Source Water Assessments

A Source Water Susceptibility Assessment for your drinking water source(s) is currently being updated by the Texas Commission on Environmental Quality (TCEQ). This information describes the susceptibility and types of constituents that may come into contact with your drinking water source based on human activities and natural conditions. The information contained in the assessment allows us to focus source water protection strategies.

The TCEQ completed an assessment of your source water and results indicate that some of your sources are susceptible to certain contaminants. The sampling requirements for your water system are based on this susceptibility and previous sample data. Any detection of these contaminants may be found in this Consumer Confident Report. For more information on source water assessments and protection efforts at our system, contact Frances Delk, Jones Water Supply Corp 903-967-2840

For more information about your sources of water, please refer to the Source Water Assessment Viewer available at the following URL:
<http://www.tceq.texas.gov/gis/swaview>

Further details about sources of source water assessments are available in Drinking Water Watch at the following URL:
<http://dww2.tceq.texas.gov/DWW/>

<u>Source Water Name</u>	<u>Type of Water</u>	<u>Report Status</u>	<u>Location</u>
1 – Forest Hill *	GW	A	1650 N ST HWY 37, Quitman, TX 75783
2 – A Well *	GW	A	4398 W FM 515, Quitman, TX 75783
3 – Forest Hill Remote/N of Plant 1 *	GW	A	CR 4918 / HWY 37, Quitman, TX 75783
4 – B Well *	GW	A	4398 W FM 515, Quitman, TX 75783
5 - Irons Well (FM 14/2088) *	GW	A	340 CR 3135, Quitman, TX 75783
6 – C Well *	GW	A	4398 W FM 515, Quitman, TX 75783
7 – Hicks Well*	GW	A	1449 CR 3118, Quitman, TX 75783

* Carrizo-Wilcox Aquifer

Water Quality Test Results

Definitions: The following tables contain scientific terms and measures, some of which may require explanation.

Maximum Contaminant Level Goal or MCLG: The level of contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Contaminant Level or MCL: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Residual Disinfectant Level Goal or MRDLG: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Maximum Residual Disinfectant Level or MRDL: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Level 1 Assessment: A study of the water system to identify potential problems & determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A very detailed study of the water system to identify potential problems & determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

ppm: milligrams per liter or parts per million

ppb: micrograms per liter or parts per billion

pCi/L: picocuries per liter. (a measure of radioactivity)

Avg: Regulatory compliance with some MCLs are based on running annual average of monthly samples.

MFL: million fibers per liter (a measure of asbestos)

NTU: nephelometric turbidity units (a measure of turbidity)

ppt: parts per trillion, or nanograms per liter(ng/L)

ppq: parts per quadrillion, or picograms per liter (pg/L)

mrem: millirems per year (a measure of radiation absorbed by the body)

Treatment Technique or TT: A required process intended to reduce the level of a contaminant in drinking water.

na: not applicable

Action Level Goal (ALG): The level of contaminant in drinking water below which there is no known or expected risk to health.

Lead & Copper	Year	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	2019	1.3	1.3	0.415	0	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of Household plumbing systems.
Lead	2016	0	15	1.9	0	ppb	N	Corrosion of household plumbing systems; Erosion of natural deposits.

Regulated Contaminants

Disinfectants and Disinfection By-Products	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Haloacetic Acids (HAA5)*	2021	1	1-1	No goal for the total	60	ppb	N	By-product of drinking water disinfection.
Total Trihalomethanes (TTHm)*	2021	13	12.6-12.6	No goal for the total	80	ppb	N	By-Product of drinking water disinfection.

* The value in the Highest Level or Average Detected column is the highest average of all HAA5 sample results collected at a location over a year.
 * The value in the Highest Level or Average Detected column is the highest average of all TTHm sample results collected at a location over a year.

Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Arsenic	2014	1.23	1.07-1.23	0	10	ppb	N	Erosion of natural deposits; Runoff from orchards; runoff from glass and electronics production wastes
Barium	2020	0.028	0.018-0.028	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Chromium	2016	1.8	0-1.8	100	100	ppb	N	Discharge from steel and pulp mills; Erosion of natural deposits.
Fluoride	2020	0.106	0.105-0.106	4	4.0	ppm	N	Erosion of natural deposits; Water additive, which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate [measured as Nitrogen]	2021	0.039	0.0196-0.039	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
Selenium	2014	5.82	4.91-5.82	50	50	ppb	N	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines.
Thallium	2014	0.448	0.262-0.448	0.5	2	ppb	N	Discharge from electronics. Glass, and leaching from ore processing sites; drug factories

Nitrate Advisory – Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant, you should ask advice from your health care provider.

Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Combined Radium 226/228	2019	1.5	1.5 – 1.5	0	5	pCi/L	N	Erosion of natural deposits.

Volatile Organic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Xylenes	2016	0.00069	0-0.00069	10	10	ppm	N	Discharge from petroleum factories; Discharge from chemical factories
Dichloromethane	2021	3	0-3.04	0	5	Ppb	N	Discharge from pharmaceutical and chemical factories.

Disinfectant	Year	Avg Level	Minimum Level	Maximum Level	MRDL	MRDLG	Unit of Measure	Violation	Likely Source of Contamination
Chlorine	2021	1.61	1.2	2.1	4.0	4.0	ppm	N	Water additive used to control microbes